

appVersion(3) = "0.98.6179"

FONT SET TO 8

Cl.:8.15.2 Development of reinforcing bars and deformed wire in tension

Cl.: 8.15.2.3: Development length

Case 1: components containing minimum stirrups or ties within l_d or slabs and walls with a clear spacing of not less than $2d_b$ between bars being developed

$$l_{d1} := 0.18 \cdot k_1 \cdot k_2 \cdot k_3 \cdot \frac{f_y}{f_{cr}} \cdot d_b$$

Case 2: all other cases

$$l_{d2} := 0.24 \cdot k_1 \cdot k_2 \cdot k_3 \cdot \frac{f_y}{f_{cr}} \cdot d_b$$

Select which case is it

$$l_d := l_{d1}$$

$$l_d := \text{Max} \left(l_d, 300 \text{ mm} \right)$$

Cl.: 8.15.2.4 Modification factors

The following modification factors shall be used in calculating the development length specified in

Clauses 8.15.2.2 and 8.15.2.3:

(a) Bar location factor, k_1 :

$$k_1 := 1.0$$

- (i) 1.3 for horizontal reinforcement placed so that more than 300 mm of fresh concrete is cast in the component below the development length or splice; and
- (ii) 1.0 for other cases.

(b) Coating factor, k_2 :

- (i) 1.5 for epoxy-coated reinforcement with a clear cover less than $3d_b$ or a clear spacing between bars being developed less than $6d_b$;
- (ii) 1.2 for all other epoxy-coated reinforcement; and
- (iii) 1.0 for uncoated reinforcement.

$$k_2 := 1.0$$

(c) Bar size factor, k_3 :

- (i) 0.8 for 20M and smaller bars and deformed wires; and
- (ii) 1.0 for 25M and larger bars.

$$k_3 := \begin{cases} 0.8 & \text{if } d_b \leq 20.01 \text{ mm} \\ 1.0 & \text{otherwise} \end{cases}$$

The product $k_1 k_2$ need not be taken greater than 1.7.

Table 8.8
Minimum development length of reinforcing bars
and deformed wire in tension
(See Clause 8.15.2.3.)

Cases	Minimum development length, ℓ_d
Components containing minimum stirrups or ties (Clause 8.9.1.3 or 8.14.4.3) within ℓ_d or slabs and walls with a clear spacing of not less than $2d_b$ between bars being developed	$0.18 k_1 k_2 k_3 \frac{f_y}{f_{cr}} d_b$
Other cases	$0.24 k_1 k_2 k_3 \frac{f_y}{f_{cr}} d_b$

Cl.: 8.15.9.3 Splices of deformed bars and deformed wire in tension

Lap splices of deformed bars and deformed wire in tension shall be classified as Class A or Class B in accordance with Table 8.11. The minimum length of lap shall be 1.0ld for Class A splices and 1.3ld for Class B splices, but not less than 300 mm. In this regard, the development length, ld, shall be calculated in accordance with Clause 8.15.2.1, but without the modification factors for excess reinforcement specified in Clause 8.15.2.5.

Table 8.11
Classification of lap splices in tension
(See Clause 8.15.9.3.)

$(A_s \text{ provided})/(A_s \text{ required})$	Maximum percentage of A_s spliced within required splice length	
	50	100
≥ 2	Class A	Class B
< 2	Class B	Class B

$$k_{spl} := 1.3$$

Concrete:

$$f'_c := 35 \text{ MPa} \quad f_{cr} := \text{Min} \left(0.4 \cdot \sqrt{f'_c \text{ MPa}}, 3.2 \text{ MPa} \right) = 2.366 \text{ MPa}$$

Steel:

$$f_y := 400 \text{ MPa}$$

$$d_{b10} := 11.3 \text{ mm}$$

$$d_{b15} := 16 \text{ mm}$$

$$d_{b20} := 19.5 \text{ mm}$$

$$d_{b25} := 25.2 \text{ mm}$$

$$d_{b30} := 29.9 \text{ mm}$$

$$d_{b35} := 35.7 \text{ mm}$$

$$l_d(d_{b\#}) := \left| l_d \right| \left\{ d_b = d_{b\#} \right. \quad l_{spl}(d_{b\#}) := k_{spl} \cdot \left| l_d \right| \left\{ d_b = d_{b\#} \right.$$

Development length:

$$l_d(d_{b15}) = 389 \text{ mm} \quad l_d(d_{b20}) = 475 \text{ mm} \quad l_d(d_{b25}) = 767 \text{ mm} \quad l_d(d_{b30}) = 910 \text{ mm} \quad l_d(d_{b35}) = 1086 \text{ mm}$$

Splice length:

$$l_{spl}(d_{b15}) = 506 \text{ mm} \quad l_{spl}(d_{b20}) = 617 \text{ mm} \quad l_{spl}(d_{b25}) = 997 \text{ mm} \quad l_{spl}(d_{b30}) = 1183 \text{ mm} \quad l_{spl}(d_{b35}) = 1412 \text{ mm}$$